



Iron Removal Filter:

Efficiency & performance:

Iron Content In Water	Volume of Water that can be treated	Period for Regeneration
Up to 5 mg/lts.	2,40,000lts.	45 days
5 - 10 mg/lts.	1,26,000lts.	30 days
10 - 50 mg/lts.	1,18,000lts.	15 days

Application:

- Hotels
- Hospital
- Housing Flats
- Tea Garden
- Industries etc